



ON-SITE SYSTEMS TECHNICAL REVIEW BOARD

SUMMARY OF ACTION



9 April 08

Members Present: Joel Neimeyer PE, Chairman, Mark Musial PE, Vice Chairman, Scott Hattenburg PE, Lori Davey Homeowner, Matt Edge PE,

Advisory Members:

Staff Present: Dan Roth, Program Manager, Jack Frost, Deputy Director of Building Safety, Deb Wockenfuss, Kathy Maricle, Permit Clerk II

Guests: Jeff Garness, President Garness Engineering Group, Ltd, Jody Maus, Garness Engineering, Tom Varney, Anchorage Tank & Welding, Jim Jensen, Anchorage Tank & Welding, Steve Pannone PE, Ted Moore PE, Mike N. Anderson PE, Steve Eng PE, Bill Reith A.D.E.C., Dave Collidge PE

Meeting called to order at 1140.

Introductions made of all present.

Dan Roth told the Board that the HDP is projected to finish by the middle of July 08, and coming up shortly will be a public meeting to be held on 21 April 08. Jeff Garness of Garness Engineering Group, Ltd., gave the Tech Board a slide presentation on the Quanics Aerocell system. Jeff explained how the system works and set up of the system, and that the system is being used in both Canada and the lower 48. Jeff was requesting that the Tech Board approve the Quanics Aerocell as a category III nitrate reducing system. The Tech Board made the following decision:

“With regard to the request by Garness Engineering for M.O.A. approval of the Quanic Aerocell Treatment Systems as a category III and nitrogen reducing technology: The Board wants 12 months of testing in accordance to the advanced wastewater code with the understanding that March 2008 data is not provided (i.e. 11 months of actual data). The Board will entertain a subsequent waiver request from Jeff Garness for shortening the 12 months of testing.”

Meeting adjourned at 1:20 pm.